



EASTERN CAMDEN COUNTY REGIONAL SCHOOL DISTRICT

Laurel Oak Rd. PO Box 2500 Voorhees, NJ 08043 856-346-6730 FAX: 856-627-7894

June 5, 2017

Dear Parents, Teachers, and Members of the Eastern Camden County Regional School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Eastern Camden County Regional tested our school’s drinking water for lead.

In accordance with the Department of Education regulations, Eastern Regional High School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a “DO NOT DRINK – SAFE FOR HANDWASHING ONLY” sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for Eastern Regional High School. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 98 samples taken, all but one (1) tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlet that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Eastern Regional High School has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
Eastern High School Room 503 – Home Economics Teacher island sink	17.6	Disconnected water service to the sink

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even

cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at www.eccrsd.us.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

Sincerely,



Dr. Harold Melleby, Jr.
Superintendent



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

David Flanigan
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

5/2/2017

Phone: (856) 848-0800
Fax: (856) 848-0838

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 4/18/2017. The results are tabulated on the attached data pages for the following client designated project:

16020-01 / Eastern Regional HS

The reference number for these samples is EMSL Order #011702915. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011702915
 CustomerID: MDS50
 CustomerPO:
 ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

Phone: (856) 848-0800
 Fax: (856) 848-0838
 Received: 04/18/17 8:30 AM

Project: 16020-01 / Eastern Regional HS

Analytical Results

Client Sample Description LW-019B
Hall Near Recital Room
Collected: 4/18/2017 **Lab ID:** 011702915-0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-019A
Hall Near 700
Collected: 4/18/2017 **Lab ID:** 011702915-0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-039
Hall Near 314
Collected: 4/18/2017 **Lab ID:** 011702915-0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-038
Hall Near A-306
Collected: 4/18/2017 **Lab ID:** 011702915-0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-036
Hall Near Medical Center 300
Collected: 4/18/2017 **Lab ID:** 011702915-0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-029A
Hall Near Gym #1
Collected: 4/18/2017 **Lab ID:** 011702915-0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-042
Girls Locker Room (Gym #1)
Collected: 4/18/2017 **Lab ID:** 011702915-0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-041
Boys Lokcer Room (Gym #1)
Collected: 4/18/2017 **Lab ID:** 011702915-0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011702915
 CustomerID: MDS50
 CustomerPO:
 ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

Phone: (856) 848-0800
 Fax: (856) 848-0838
 Received: 04/18/17 8:30 AM

Project: 16020-01 / Eastern Regional HS

Analytical Results

Client Sample Description LW-041
 Boys Lokcer Room (Gym #1) **Collected:** 4/18/2017 **Lab ID:** 011702915-0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-037
 Hall Nr A-401 **Collected:** 4/18/2017 **Lab ID:** 011702915-0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-035
 Hall Outside of 500 Cafeteria **Collected:** 4/18/2017 **Lab ID:** 011702915-0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-025B
 500 Cafeteria-Kitchen Food Prep Sink **Collected:** 4/18/2017 **Lab ID:** 011702915-0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.30	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-025A
 500 Cafeteria-Kitchen Double Food Prep Sink **Collected:** 4/18/2017 **Lab ID:** 011702915-0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.43	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-040
 Maintenance Break Room **Collected:** 4/18/2017 **Lab ID:** 011702915-0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-018B
 Hall Near Gym #2 **Collected:** 4/18/2017 **Lab ID:** 011702915-0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG

Client Sample Description LW-018C
 Hall Near Gym #2 **Collected:** 4/18/2017 **Lab ID:** 011702915-0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011702915
 CustomerID: MDS50
 CustomerPO:
 ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

Phone: (856) 848-0800
 Fax: (856) 848-0838
 Received: 04/18/17 8:30 AM

Project: 16020-01 / Eastern Regional HS

Analytical Results

Client Sample Description		LW-018C Hall Near Gym #2	Collected:	4/18/2017	Lab ID:	011702915-0015		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG
Client Sample Description		LW-017C Hall Near Guidance Office	Collected:	4/18/2017	Lab ID:	011702915-0016		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG
Client Sample Description		LW-017D Hall Near Guidance Office	Collected:	4/18/2017	Lab ID:	011702915-0017		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG
Client Sample Description		LW-018A Hall Near 806	Collected:	4/18/2017	Lab ID:	011702915-0018		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG
Client Sample Description		LW-016A Glass Hall Near Auditorium	Collected:	4/18/2017	Lab ID:	011702915-0019		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG
Client Sample Description		LW-015A Nurse's Office Fountain	Collected:	4/18/2017	Lab ID:	011702915-0020		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/20/2017	SM	4/21/2017	EG
Client Sample Description		LW-014A Main Foyer- Near Bathroom	Collected:	4/18/2017	Lab ID:	011702915-0021		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM
Client Sample Description		LW-014B Main Foyer- Near Bathroom	Collected:	4/18/2017	Lab ID:	011702915-0022		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011702915
 CustomerID: MDS50
 CustomerPO:
 ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

Phone: (856) 848-0800
 Fax: (856) 848-0838
 Received: 04/18/17 8:30 AM

Project: 16020-01 / Eastern Regional HS

Analytical Results

Client Sample Description LW-014B **Collected:** 4/18/2017 **Lab ID:** 011702915-0022
 Main Foyer- Near Bathroom

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-003D **Collected:** 4/18/2017 **Lab ID:** 011702915-0023
 Gym #4

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-013A **Collected:** 4/18/2017 **Lab ID:** 011702915-0024
 Outside 50 Hallway

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-013B **Collected:** 4/18/2017 **Lab ID:** 011702915-0025
 Outside 50 Hallway

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-012E **Collected:** 4/18/2017 **Lab ID:** 011702915-0026
 Outside 70 Hallway

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/1/2017	EG	5/2/2017	EG

Client Sample Description LW-012A **Collected:** 4/18/2017 **Lab ID:** 011702915-0027
 Hall Near S1

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-012B **Collected:** 4/18/2017 **Lab ID:** 011702915-0028
 Hall Near S1

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-012C **Collected:** 4/18/2017 **Lab ID:** 011702915-0029
 Hall Near S1

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011702915
 CustomerID: MDS50
 CustomerPO:
 ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

Phone: (856) 848-0800
 Fax: (856) 848-0838
 Received: 04/18/17 8:30 AM

Project: 16020-01 / Eastern Regional HS

Analytical Results

Client Sample Description LW-012C
Hall Near S1 **Collected:** 4/18/2017 **Lab ID:** 011702915-0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-0010A
90 Hall - Near Bathrooms **Collected:** 4/18/2017 **Lab ID:** 011702915-0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-009C
30 Hall - Near Bathrooms **Collected:** 4/18/2017 **Lab ID:** 011702915-0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-009D
30 Hall - Near Bathrooms **Collected:** 4/18/2017 **Lab ID:** 011702915-0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-009A
30 Hall - Near Bathrooms **Collected:** 4/18/2017 **Lab ID:** 011702915-0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-009B
30 Hall - Near Bathrooms **Collected:** 4/18/2017 **Lab ID:** 011702915-0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-007A
20 Café Hall **Collected:** 4/18/2017 **Lab ID:** 011702915-0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-003B
Hall Near Mach Room #3 **Collected:** 4/18/2017 **Lab ID:** 011702915-0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011702915

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

Phone: (856) 848-0800
 Fax: (856) 848-0838
 Received: 04/18/17 8:30 AM

Project: 16020-01 / Eastern Regional HS

Analytical Results

Client Sample Description LW-003B
Hall Near Mach Room #3
Collected: 4/18/2017
Lab ID: 011702915-0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-003C
Hall Near Mach Room #3
Collected: 4/18/2017
Lab ID: 011702915-0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-003A
Room 18
Collected: 4/18/2017
Lab ID: 011702915-0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-004B
Hall Near Room 17
Collected: 4/18/2017
Lab ID: 011702915-0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.44	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Client Sample Description LW-004C
Hall Near Room 17
Collected: 4/18/2017
Lab ID: 011702915-0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/25/2017	AE	4/25/2017	SM

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

David Flanigan
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

5/3/2017

Phone: (856) 848-0800
Fax: (856) 848-0838

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 4/21/2017. The results are tabulated on the attached data pages for the following client designated project:

16020-01 / Eastern Regional HS

The reference number for these samples is EMSL Order #011703052. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011703052
 CustomerID: MDS50
 CustomerPO:
 ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

Phone: (856) 848-0800
 Fax: (856) 848-0838
 Received: 04/21/17 9:00 AM

Project: 16020-01 / Eastern Regional HS

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>					
LW-050 500 Cafeteria - Fountain		4/21/2017	011703052-0001					
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
LW-05A 500 Cafeteria - Fountain		4/21/2017	011703052-0002					
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
LW-024A 500 Café - Fac Dinning - Ice Machine		4/21/2017	011703052-0003					
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
LW-043 505 Culinary Arts - Sink		4/21/2017	011703052-0004					
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
LW-044 505 Culinary Arts - Sink		4/21/2017	011703052-0005					
200.8	Lead	1.11	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
LW-045 505 Culinary Arts - Sink		4/21/2017	011703052-0006					
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
LW-046 505 Culinary Arts - Sink		4/21/2017	011703052-0007					
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
LW-047 505 Culinary Arts - Sink		4/21/2017	011703052-0008					
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011703052
 CustomerID: MDS50
 CustomerPO:
 ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

Phone: (856) 848-0800
 Fax: (856) 848-0838
 Received: 04/21/17 9:00 AM

Project: 16020-01 / Eastern Regional HS

Analytical Results

Client Sample Description		LW-047 505 Culinary Arts - Sink	Collected:	4/21/2017	Lab ID:	011703052-0008		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-048 503 Culinary Arts - Sink	Collected:	4/21/2017	Lab ID:	011703052-0009		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.76	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-048A 503 Culinary Arts - Sink	Collected:	4/21/2017	Lab ID:	011703052-0010		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.6	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-049A Concession Stand - Ice Machine	Collected:	4/21/2017	Lab ID:	011703052-0011		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-049 Concession Stand - Ice Machine	Collected:	4/21/2017	Lab ID:	011703052-0012		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-051 Gym #2 - Boys Locker Room	Collected:	4/21/2017	Lab ID:	011703052-0013		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-053 Gym #2 - Girls Locker Room	Collected:	4/21/2017	Lab ID:	011703052-0014		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-053A Gym #2 - Girls Locker Room	Collected:	4/21/2017	Lab ID:	011703052-0015		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011703052
 CustomerID: MDS50
 CustomerPO:
 ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

Phone: (856) 848-0800
 Fax: (856) 848-0838
 Received: 04/21/17 9:00 AM

Project: 16020-01 / Eastern Regional HS

Analytical Results

Client Sample Description		LW-053A Gym #2 - Girls Locker Room	Collected:	4/21/2017	Lab ID:	011703052-0015		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-052 Trainer's Room - Ice Machine	Collected:	4/21/2017	Lab ID:	011703052-0016		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-054 Weight Room - Fountain	Collected:	4/21/2017	Lab ID:	011703052-0017		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-054A Weight Room - Fountain	Collected:	4/21/2017	Lab ID:	011703052-0018		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-004A Room 17 - Sink	Collected:	4/21/2017	Lab ID:	011703052-0019		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-005A 20 Café - Ice Machine	Collected:	4/21/2017	Lab ID:	011703052-0020		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-005B 20 Café - Water Cooler	Collected:	4/21/2017	Lab ID:	011703052-0021		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.26	1.00	µg/L	4/24/2017	AE	4/25/2017	SM
Client Sample Description		LW-006A 20 Café Kitchen - Sink	Collected:	4/21/2017	Lab ID:	011703052-0022		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703052

CustomerID: MDS50

CustomerPO:

ProjectID:

Attn: **David Flanigan**
Horizon Environmental Group, Inc.
PO Box 316
Thorofare, NJ 08086

Phone: (856) 848-0800
 Fax: (856) 848-0838
 Received: 04/21/17 9:00 AM

Project: 16020-01 / Eastern Regional HS

Analytical Results

Client Sample Description LW-006A **Collected:** 4/21/2017 **Lab ID:** 011703052-0022
 20 Café Kitchen - Sink

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM

Client Sample Description LW-006B **Collected:** 4/21/2017 **Lab ID:** 011703052-0023
 20 Café Kitchen - Sink

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	4/24/2017	AE	4/25/2017	SM

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)